





NOTE

Duplex convenience receptacles shall have ground fault circuit interrupter as defined by the Code. Circuit interruption shall occur on 6 mA of ground fault current and shall not occur on less than 4 mA. Receptacles shall be installed in a weatherproof housing with rainproof lift covers.



IRRIGATION CONTROLLER
ENCLOSURE CABINET
WIRING DIAGRAM
(TYPICAL)



PLAN

Conduit from electric service

ò

27C

Concrete pad

Irrigation

controller

enclosure

Joint

Concrete

foundation

Irrigation controller-

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

ELECTRICAL SYSTEMS (IRRIGATION CONTROLLER ENCLOSURE CABINET)

NO SCALE

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

ES-3H